

Our simple ten-point checklist gives you an overview of what to consider when inspecting your company's Fire Doors.

	YES	NO
Are your Fire Doors certificated (label or plug)?	<input type="checkbox"/>	<input type="checkbox"/>
Are the gaps between the leaf and frame 3mm (+/- 1mm)?	<input type="checkbox"/>	<input type="checkbox"/>
Are the intumescent/cold smoke seals damaged or missing?	<input type="checkbox"/>	<input type="checkbox"/>
Are the hinges all firmly fixed with no screws missing?	<input type="checkbox"/>	<input type="checkbox"/>
Do all handles and panic hardware operate correctly?	<input type="checkbox"/>	<input type="checkbox"/>
Are the doors able to close in a controlled manner and are they free from obstruction?	<input type="checkbox"/>	<input type="checkbox"/>
Do door selectors operate correctly?	<input type="checkbox"/>	<input type="checkbox"/>
Is the glass secure in the frame?	<input type="checkbox"/>	<input type="checkbox"/>
Do the doors display the correct signage and is it legible?	<input type="checkbox"/>	<input type="checkbox"/>
Have your doors been inspected by a trained industry professional?	<input type="checkbox"/>	<input type="checkbox"/>

To find out more about Fire Doors and how Churches Fire & Security can help you and your business requirements, call us on 0370 608 4350.